

**_100 kW Baldor Generator, John Deere Engine, Year - 2011, Open Skid,
201 Hours, US EPA Tier 3, Non After Treatment**



Fuel Diesel

Year 2011

Voltage 240/120 Volts

Hours 201 Hours

Phase 1 Phase

Make Baldor

Model DLC100-3J

Serial P1104050004

Hertz 60 Hz

Wires 4 Lead

Kilo Watts 100 kW

Mounted Skid Mounted

Fuel Tank Base Fuel Tank

Length 80"

Width 32"

Height 54"

Weight 3000 lbs

Condition Well Maint. Unit, Tested, Serviced, Ready to go

Circuit Breaker Yes