

20 kW MTU Generator with Isuzu Engine, Enclosed with Base Fuel Tank, Year - 2016, 122 Hours, US EPA Tier 3



Fuel Diesel

Year 2016

Voltage 120/240 Volts

Hours 122 Hours

Phase 1/3 Phase

Make MTU

Model DG04RZ055V1M00003

Serial 95070600009

Hertz 60 Hz

Wires 12 Lead

Kilo Watts 20 kW

Mounted Skid Mounted

Fuel Tank Base Fuel Tank

Enclosure Sound Attenuated

Enclosed Enclosed

Lead Reconnectable

Length 84"

Width 30"

Height 78"

Weight 2500 lbs

Condition Well Maint. Unit, Tested, Serviced, Ready to go

Circuit Breaker Yes