

**500 kW Katolight Generator, Volvo Penta Engine, Year - 2002, Enclosed,
Base Fuel Tank, 502 Hours**



Fuel Diesel

Year 2002

Voltage 120/208 Volts

Hours 502 Hours

Phase 1/3 Phase

Make Katolight

Model D500FPV4

Serial VA533730

Hertz 60 Hz

Wires 12 Lead

Kilo Watts 500 kW

Mounted Skid Mounted

Fuel Tank Base Fuel Tank

Enclosed Enclosed

Lead Reconnectable

Length 156"

Width 72"

Height 120"

Weight 15000 lbs

Condition Well Maint. Unit, Tested, Serviced, Ready to go

Circuit Breaker Yes